

We use some essential cookies to make this service work.

We'd also like to use analytics cookies so we can understand how you use the service and make improvements.

[Accept analytics cookies](#)

[Reject analytics cookies](#)

[View cookies](#)

[Back](#)

# Energy performance certificate (EPC)

## Certificate contents

- Rules on letting this property
- Energy rating and score
- Breakdown of property's energy performance
- How this affects your energy bills
- Impact on the environment
- Changes you could make
- Who to contact about this certificate
- Other certificates for this property

## Share this certificate

[Email](#)

[Copy link to clipboard](#)

[Print](#)

41 Evesham Road LEICESTER LE3 2BE	Energy rating <b>D</b>
---	---------------------------

Valid until <b>15 March 2033</b>	Certificate number <b>9866-0050-7267-9217-3240</b>
-------------------------------------	---

Property type	Mid-terrace house
---------------	-------------------

Total floor area	106 square metres
------------------	-------------------

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](#).

## Energy rating and score

This property's current energy rating is D. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, no insulation (assumed)	Very poor
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer and room thermostat	Average
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 332 kilowatt hours per square metre (kWh/m<sup>2</sup>).

[About primary energy use](#)

## How this affects your energy bills

An average household would need to spend **£1,238 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £318 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 20,606 kWh per year for heating
- 2,257 kWh per year for hot water

## Impact on the environment

This property's current environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

### Carbon emissions

An average household produces	6 tonnes of CO <sub>2</sub>
-------------------------------	-----------------------------

This property produces	6.2 tonnes of CO <sub>2</sub>
------------------------	-------------------------------

This property's potential production	3.4 tonnes of CO <sub>2</sub>
--------------------------------------	-------------------------------

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

[Do I need to follow these steps in order?](#)

### Step 1: Internal or external wall insulation

Typical installation cost	£4,000 - £14,000
---------------------------	------------------

Typical yearly saving	£206
-----------------------	------

Potential rating after completing step 1	<b>62 D</b>
--	-------------

### Step 2: Floor insulation (solid floor)

Typical installation cost	£4,000 - £6,000
---------------------------	-----------------

Typical yearly saving	£41
-----------------------	-----

Potential rating after completing steps 1 and 2	<b>64 D</b>
---	-------------

### Step 3: Heating controls (thermostatic radiator valves)

Heating controls (TRVs)

Typical installation cost	£350 - £450
---------------------------	-------------

Typical yearly saving	£40
-----------------------	-----

Potential rating after completing steps 1 to 3	<b>65 D</b>
--	-------------

### Step 4: Solar water heating

Typical installation cost	£4,000 - £6,000
---------------------------	-----------------

Typical yearly saving	£31
-----------------------	-----

Potential rating after completing steps 1 to 4	<b>66 D</b>
--	-------------

### Step 5: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
---------------------------	-----------------

Typical yearly saving	£356
-----------------------	------

Potential rating after completing steps 1 to 5	<b>75 C</b>
--	-------------

### Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme](#). This will help you buy a more efficient, low carbon heating system for this property.

### More ways to save energy

[Find ways to save energy in your home.](#)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Adam Amujee
-----------------	-------------

Telephone	07585778994
-----------	-------------

Email	<a href="mailto:adams.energysolutions@gmail.com">adams.energysolutions@gmail.com</a>
-------	--

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
----------------------	--------------------------

Assessor's ID	STRO028405
---------------	------------

Telephone	0330 124 9660
-----------	---------------

Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>
-------	--

### About this assessment

Assessor's declaration	No related party
------------------------	------------------

Date of assessment	16 March 2023
--------------------	---------------

Date of certificate	16 March 2023
---------------------	---------------

Type of assessment	<a href="#">RdSAP</a>
--------------------	-----------------------

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluic.digital-services@levellingup.gov.uk](mailto:dluic.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	<a href="#">8008-5189-3929-4606-1623</a>
--------------------	--

Expired on	7 June 2022
------------	-------------